



TRTC-0654-N1 Backup Times (Two Battery Strings)

Please note: Runtimes are based on new unused batteries. Lead acid batteries will experience decreased runtimes by ~10-15% after ~20 cycles and due to factors, such as ambient temperature, number of charge-discharge cycles, and improper storage or handling.

Туре	162.5W	325W	487.5W	650W
	25%	50%	75%	100%
28Ah	5hrs 30min	2hrs 40min	1hr 35min	1hr
48Ah	8hrs 30min	5hrs	3hrs 20min	2hrs 20min
79Ah	13hrs 45min	7hrs 25min	4hrs 40min	3hrs 20min
105Ah	16hrs 20min	9hrs 30min	5hrs 45min	4hrs 20min

