



TRTC-1124-N1 Backup Times (One Battery String)

Tel: 310-689-2328

Please note: Runtimes are based on new unused batteries. Lead acid batteries will experience decreased runtimes by ~10-15% after ~20 cycles and due to factors, such as ambient temperature, number of charge-discharge cycles, and improper storage or handling.

Туре	275W	550W	825W	1100W
	25%	50%	75%	100%
28Ah	1hr 25min	50min	30min	20min
48Ah	2hrs 45min	1hr 30min	56min	36min
79Ah	3hrs 53min	2hrs 11min	1hr 17min	50min
105Ah	5hrs 42min	3hrs	1hr 53min	1hr 25min

