

**6000VA Tower Model**

Configuration	VTWP-6000-02 (UPS) and VTPB-0007-240 (EBP) Backup Times in Minutes									
% of Max Load (Watts)	10	20	30	40	50	60	70	80	90	100
UPS ONLY	56	33	21	17	12	9.5	8	6.5	5.5	4.5
UPS + 1 Battery Pack	220	130	86	70	54	43	37	31	27	24
UPS + 2 Battery Packs	400	242	162	130	100	82	70	59	53	46
UPS + 3 Battery Packs	584	360	244	194	150	123	105	89	80	70
UPS + 4 Battery Packs	780	475	327	262	203	166	142	121	108	95

**10000VA Tower Model**

Configuration	VTWP-10000-02 (UPS) and VTPB-0009-240 (EBP) Backup Times in Minutes									
% of Max Load (Watts)	10	20	30	40	50	60	70	80	90	100
UPS ONLY	36	21	13.5	11.5	8.7	6.7	5.5	4.3	3.8	3.2
UPS + 1 Battery Pack	120	70	46	37	28	22	18	15	13	11
UPS + 2 Battery Packs	220	130	86	70	54	43	37	31	27	24
UPS + 3 Battery Packs	327	196	130	105	81	66	56	48	42	37
UPS + 4 Battery Packs	434	265	177	142	110	90	77	65	58	51

**6000VA 19" Rack- Mount Model**

Configuration	VRTP-6000-02 (UPS) and VRPB-0007-240 (EBP) Backup Times in Minutes									
% of Max Load (Watts)	10	20	30	40	50	60	70	80	90	100
UPS + 1 Battery Pack	55	32	20	17	12	9.5	8	6.5	5.5	4.5
UPS + 2 Battery Packs	134	78	52	42	31	26	21	18	16	13
UPS + 3 Battery Packs	220	130	85	70	53	43	37	31	27	24
UPS + 4 Battery Packs	310	183	123	99	75	62	53	45	40	35

**10000VA 19" Rack- Mount Model**

Configuration	VRTP-10000-02 (UPS) and VRPB-0009-240 (EBP) Backup Times in Minutes									
% of Max Load (Watts)	10	20	30	40	50	60	70	80	90	100
UPS + 1 Battery Pack	35	20	13	11	8	6	5	4	3.5	3
UPS + 2 Battery Packs	80	48	32	26	20	16	14	12	10	9.5
UPS + 3 Battery Packs	125	77	53	42	33	27	23	19	17	15
UPS + 4 Battery Packs	175	106	74	60	47	38	33	28	25	22